



**City of Jasper**  
200 Burnt Mountain Road  
Jasper, GA 30143  
Phone: 706-692-9100  
Fax: 706-692-9109

Mayor  
Steve Lawrence

City Manager  
Sonia Jammes

Mayor Pro Tem  
Kirk Raffield  
Council  
John B Foust, Jr  
Anne Sneve  
Dr Folsom Proctor III  
Jim Looney

---

**City of Jasper**

**Request for Proposals for Lease of Municipal Real Estate for  
Telecommunications Tower and Equipment Shelter  
RFP 2023-11**

**Addendum No. 3  
October 23, 2023**

**1. Is a structural analysis required? If so, will the City accept analyses that are over 5 years old?**

*Please refer to Section 4.3 "Telecommunications Equipment Designs and Intentions". Respondents are required to provide a structural analysis by a qualified engineer that the Respondent's telecommunication towers, accounting for all towers on the property and/or up to four (4) cell towers upon the water tank will not adversely affect the structural integrity and maintenance of the water tank, the property, and any existing structure on the property.*

*The City must have a way to determine how many cell towers the Lilly tank can safely handle. We can accept a previously prepared analysis as long as the analysis provides information on the capacity of the tank to hold multiple towers.*

**2. Considering carrier equipment is considered proprietary, will the City accept a structural analysis for only the equipment intended for the respondent?**

*The analysis must address the capacity of the tank to handle multiple towers from both an operational standpoint as to the water tank, and so the City is aware of how many towers it may safely hold. We are happy to hold all proprietary information as confidential; however, the envelope holding the analysis must be properly marked as confidential.*