

ADDENDUM NO. ONE
TO
BID DOCUMENTS, CONTRACT DOCUMENTS,
CONSTRUCTION SPECIFICATIONS AND DRAWINGS
FOR
WATER SYSTEM IMPROVEMENTS
LONG SWAMP CREEK DREDGING
FOR THE
CITY OF JASPER, GEORGIA
PROJECT NO. 212443

Bids Received Until 2:00 p.m. Thursday, July 11, 2024

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY INSERTING ITS NUMBER IN THE PROPOSAL. FAILURE TO DO SO MAY SUBJECT BONA FIDE BIDDERS TO DISQUALIFICATION. THIS ADDENDUM FORMS A PART OF THE PROJECT DOCUMENTS; IT MODIFIES THEM AS FOLLOWS:

July 8, 2024



RESPONSE TO QUESTIONS

1. Can the dredging be performed “wet”, using traditional dredging methods, or must it be performed “dry” as posted in the advertisement? It can be advantageous from a cost and impact perspective to perform “wet” but we understand that is not always possible nor is it always the better alternative.

The work is to be conducted in the “dry” by temporarily diverting Long Swamp Creek into the emergency spillway, around the dam, and return its stream flow to the original channel near the Cove Road bridge. Work also includes repairing the storm damaged emergency spillway.

In the “dry” means Long Swamp Creek is flowing through the emergency spillway while dredging.

Time allotted for dredging is 5 consecutive calendar days.

2. Is the reason for the dredging purely built-up sediment resulting in a reduced pool?

Yes

3. Are there pollutants or contaminants suspected in the sediment?

According to the Tier I Dredge Evaluation dated February 8, 2024, “No sources of possible contamination or any contaminants of concern were identified; therefore, Terracon does not consider the proposed dredge material to be a possible ‘carrier of contaminants’.”

4. Would the City consider an alternative plan so long as the results accomplished were the same?

The current plan has been approved by US Fish and Wildlife Service and US Army Corp of Engineers. Any alternative plan must meet US Fish and Wildlife Service and US Army Corp of Engineers requirements. Most, if not all requirements are noted on the plans.

5. Should an alternative plan be proposed, how would that need to be reflected in the bid packet?

We have not received any proposed alternative plans.

END OF ADDENDUM NO. ONE